

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20141007-S8107  
**Report Reference** S8107-20110812  
**Issue Date** 2014-OCTOBER-07

**Issued to:** SOUNDTUBE ENTERTAINMENT  
6430 Business Park Loop Rd  
Park City UT 84098-6221

**This is to certify that  
representative samples of**

**SPEAKERS**

General Purpose Signaling Speaker for indoor dry locations and are suitable for use in air handling spaces, Models: CM42-EZs-II, CM62-EZ-II, CM62-EZs-II, CM82-EZ-II, CM82-EZs-II, and CM89-EZ

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 1480, Speakers for Fire Alarm, Emergency, and Commercial and Professional Use. UL 2043, Fire Test for Heat and Visible Smoke Release for Discrete Products and Their Accessories Installed in Air-Handling Spaces. CSA C22.2 No. 205-12, Signal Equipment

**Additional Information:**

See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

